



MUNICIPAL CORPORATION OF DELHI
(Office of the Deputy Health Officer)
Public Health Department: Karol Bagh Zone
Anand Parbat, New Delhi - 110005
Phone No. 011-25818502,
E-mail ID No. dhokbz@gmail.com

75
Azadi Ka
Amrit Mahotsav

No. DHO/KBZ/2025/ 188

Dated:- 01/05/2025

School Health Certificate

- | | |
|--|---------------------------------------|
| 1. Name of School | : Bajaj Public School |
| 2. Location of the School | : Street No 4, Prem Nagar, New Delhi- |
| 3. Timing of School | : 8:00 A.M. to 1.30 P.M. |
| 4. No. of Students | : 800 |
| 5. No. of Staff | : 42 |
| 6. No. of Class Rooms | : 23 |
| 7. Building Structure | : Lantered |
| 8. Electricity | : BSES Connection |
| 9. Water Supply | : Delhi Jal Board Water Supply |
| 10. No. of Toilets for Boys | : 10 |
| 11. No. of Toilets for Girls | : 15 |
| 12. No. of Indian Seats | : 21 |
| 13. No. of European | : 04 |
| 14. No. of Urinal | : 10 |
| 15. The first aid box | : Available |
| 16. The class rooms found well ventilated and neat and clean | |

At the time of inspection, School is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

The premises found fit having no objection from the Health point of view

This certificate/NOC is valid for one year from the date of issue or expiry of fire safety certificate whichever is earlier.

The Principal
Bajaj Public School
Street No 4, Prem Nagar
New Delhi


Deputy Health Officer
Karol Bagh Zone



Deputy Health Officer
Karol Bagh Zone, MCD Delhi





**DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



TEST REPORT

Sample ID	Ref. No. D.J.B./DTQC/Wzd./2025-26/Paid-1		
Location /Address of Sample	Bajaj Public School, Street No-4, Prem Nagar, New Delhi-110008		
Letter Reference No.	BPS/DJB/3/2025	Ref. Letter Date	29.03.2025
Challan No.	003	Challan Date	01.04.2025
Sample Collection date	04.04.2025	Analysis start date	04.04.2025
Any other Information	--	Analysis end date	06.04.2025
		Reporting date	07.04.2025

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet (DJB supply from storage tank)	Outlet (drinking water tap)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.7	1.1
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.49	7.55
5	Electrical Conductivity	µS/cm	-	-	733	314
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	476	204
7	Total Alkalinity	mg/L	200(Max)	600(Max)	172	82
8	Total Hardness	mg/L	200(Max)	600(Max)	178	118
9	Calcium as Ca	mg/L	75(Max)	200(Max)	48	36
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	13.9	6.7
11	Iron	mg/L	1.0(Max)	No relaxation	0.14	0.08
12	Chloride	mg/L	250(Max)	1000(Max)	92	37
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.73	0.52
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	15.5	5.6
16	Sulphate	mg/L	200(Max)	400(Max)	46.5	20.6
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	0.41	0.30
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: Water samples confirm specification for tested parameters and can be considered for the drinking purpose.

[Signature]
Tested by
Lab.Tech.

[Signature]
Verified for Chemical parameters
Asstt.Chemist

[Signature]
Verified for MPN
Asstt.Bact.

[Signature]
Authorized by
Chemist

Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad

ACWA(WZD)

